

#### **TYPE D210 ELECTRONIC PILOT ACTUATOR**

#### **APPLICATION DATA**

Building Control Systems

#### **RATINGS**

D210 120VAC, 50-60HZ, .3 AMPS Servo-Amplifier 120VAC, 50-60HZ, .3 AMPS B.U. Power Supply 120VAC, 60HZ, up to 6 AMPS

#### INPUT SIGNALS

1-5mA 10-50mA 4-20mA Selectable from 0-24 VDC

Canadian Registration # OC 0591.9C

# SPENCE

# TYPE D210 ELECTRONIC ACTUATOR PILOT WITH MODULATING SERVO-AMPLIFIER

CONTROLS to 150 PSIG

- Modulate Process Variable in Relation to a Proportional Control Input Signal
- Servo-Amplifier provides Continuous Signal for Immediate Response
- Ambient Temperatures 20 to 120°F (-7 to 49°C)
- For use with Balanced Main Valve only

#### **OPTIONS**

- Back-up Power Supply for up to 6 hours continued service during power failure.
- Explosion proof actuator, NEMA
- Fail-Safe Device to stroke Actuator half or full open on input signal failure.

#### Typical Configurations

4-20 MA Proportional Control ......ED210

### **TYPE D210**

# ELECTRONIC ACTUATOR PILOT WITH MODULATING SERVO-AMPLIFIER


#### **SPECIFICATION**

The Actuator Pilot shall maintain a system and modulate that system as requirements dictate. A continuous signal (1-5mA, 4-20mA, 10-50mA or 0-24 VCD) is transmitted by the system control to the Servo-Amplifier which positions the Actuator Pilot. In the event of a power failure, the Actuator Pilot shall stop in its present position unless a back-up power supply is specified. Such backup power supply shall provide a minimum of specified hours of operation and be maintained in a fully charged standby condition automatically.


In the event of signal failure, the Actuator Pilot shall close unless a Fail-Safe Device is specified in the Servo-Amplifier which will be factory set to stoke the Actuator Pilot half open or full open.

#### MATERIALS OF CONSTRUCTION

| Body, Cast Iron    | ASTM 126 Cl. B               |
|--------------------|------------------------------|
| Body, Carbon Steel | ASTM 216 Gr. WCB             |
| Stem3              | 03 St. Stl. ASTM 582 Cond. A |
| Disc440            | St. Stl. ASTM 276-75 Cond. A |
| Seat3              | 04 St. Stl. ASTM 276 Cond. A |
| Gasket             | Non-asbestos                 |



## TYPE D210 ELECTRONIC ACTUATOR PILOT



**TYPE D210 SERVO-AMPLIFIER** 

